



## FIRE RESISTANT TIMBER FIRE DOORS

***Certificate number: FRTD605***

This is a product certificate to certify that

***Elcir***

Postcode 11-29091  
Mkalles Main Road  
Beirut  
Lebanon  
Tel: +961 1 690 701

Who fabricate the following fire doors:

**Halspan FD30      Halspan FD90**  
**Halspan FD60      Halspan FD120**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 22**, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 120 minutes integrity** are detailed in the schedules referenced below.

Schedule ref: HS01, HS02, HS03, HS04, HS05, HS06,



First Issued: 19 March 2012  
Valid to: 18 March 2017  
Issue No: 1



175

Bob Williams  
Director of Certification

Peter Jackman  
Technical Director

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.